

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/2024/School/WZ/ 1022

Dated: 15/10/2024

FIRE SAFETY CERTIFICATE

Certified that The Heritage School, Plot No.8, Sector-23, Rohini, Delhi-110085, comprised of Basement + Ground + Three upper floors owned/occupied by The Heritage School, has already been issued FSC by this department vide letter No. F.6/DFS/MS/2021/School/WZ/813 dated 05.10.2021. The premises was re-inspected by the officer concerned of this department on 30.09.2024 in the presence of Smt. Yakshi Gulati (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy under Educational "Group B" with effect from 15/10/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/10/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to :-

1. The Principal, The Heritage School, Plot No.8, Sector-23, Rohini, Delhi-110085.
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The basement shall only be used as per BBL 1983.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms


PRINCIPAL CUM MANAGER



**THE HERITAGE SCHOOL
PLOT NO. 8, SECTOR-23
ROHINI, DELHI-110 085**

Scanned with CamScanner